

## NOTE: Element with 4" x 4" fins CANNOT be used.

- (1) Fasten hanger strip to wall at required height. Ensure strip is level and that the hanger strip runs the entire length of enclosure.
- 2 Mount BKTEO brackets at required distance below the hanger strip.
- 3 For 2 tier elements, mount and fasten BKTEO brackets at 6" spacings.
- 4 Install cradles onto brackets by placing cradle on bracket and insert the plastic fastener through the slot in the cradle into the hole in the bracket.
- 5 Install heating element onto BKTEO brackets, ensure tubing rests on cradle.

- (7) For 2 or more side by side enclosure panels, join by an internal panel joiner. (See Detail 'A')
- (8) If an access panel is used, join access panel to enclosure panel by a joiner strip and an additional mounting bracket. (not shown)
- Place trim strip on top of enclosure panel and swing bottom of trim down to wall and fasten to wall. For corners (9a), fasten at top and bottom by #10 screws.
- 10 If an access door is required, locate it on enclosure panel, cut out a 5 1/2" square opening and drill four 1/4" diameter holes on corners of 6 1/2"square. Mount and fasten access door assembly.
- (1) Correct element orientation when using 2 3/4" x 4" element for slimline enclosure.